



NOTE:  
 1. OUTSIDE CLOSURE  
 REQUIRED FOR BLDG.  
 SLOPES 1 1/2 : 12 OR  
 LESS.  
 2. CAP FLASHING REQ'D.  
 FOR BLDG. SLOPES  
 GREATER THAN 1 1/2 : 12.

SCALE: NONE

DATE:

DRAWN BY: EC

7/7/04

CHECKED BY:

ROLL-LOK CLEATED RAKE  
 STARTING END W/THERMAL BLOCK  
 ON FRAMING



DWG NO:

RL.2.C.2